



## Test Report

ULR No. TC176792600001876F

Test Report No.	AETRL/120526W0001	D/o Report Issue	15/05/2026
Dispatch No	2268	D/o Sample received	12/05/2026
Company Name	To, The Principal (Vidhya Bhavan Public School)	Qty of sample	1.0 Ltr
Address	Kavi Nagar Airport Road Gwalior Gwalior M.P	Sample bottle	Poly Bottle
Nature of Sample	Water		
Sample Collected By	Customer	D/o Sample Collection	12/05/2026
Sample Description	RO Water	Sample Received by	AETRL LAB
Sample Location	Vidhya Bhavan Public School	Sampling Method	NA
Coordinates	NA	Sample Condition	Satisfactory
D/o Sample Analysis	12/05/2026	D/o Analysis Completion	15/05/2026

## Results

S.No.	Test Parameters	Units	Results	Requirement as per IS:10500-2018		Test Method
				Acceptable Limits	Permissible Limits	
1	pH (at 25°C)	-	6.77	6.5 to 8.5	No Relaxation	IS:3025 (Part-11) 2022
2	Colour	Hazen	BDL (LOD 0.1)	5	15	IS:3025 (Part-4) 2021
3	Odour	-	Agreeable	Agreeable	Agreeable	IS:3025 (Part-5) 1983
4	Taste	-	Agreeable	Agreeable	Agreeable	IS:3025 (Part-7&8)
5	Turbidity	NTU	BDL	1	5	IS:3025 (Part-10) 2023
6	Total Dissolved Solids	mg/l	104	500	2000	IS:3025 (Part-16) 2023
7	Total Hardness as CaCO3	mg/l	23.5	200	600	IS:3025 (Part-21)
8	Calcium as Ca	mg/l	3.92	75	200	IS:3025 (Part-40) 1991
9	Magnesium as Mg	mg/l	3.33	30	100	IS:3025 (Part-46) 2023
10	Chloride as Cl	mg/l	16.6	250	1000	IS:3025 (Part-32)1988
11	Free residual chlorine	mg/l	BDL	0.2	1	IS:3025 (Part-26)
12	Total Alkalinity as CaCO3	mg/l	53.4	200	600	IS:3025 (Part-23) 2023
13	Sulphate as SO4	mg/l	11.4	200	400	IS:3025 (Part-24)
14	Nitrate as NO3	mg/l	5.37	45.0	No Relaxation	IS:3025 (Part-34)
15	Fluoride as F	mg/l	0.037	1.0	1.5	IS:3025 (Part-60)2023
16	Iron as Fe	mg/l	BDL (LOD 0.02)	0.3	No Relaxation	IS:3025 (Part-65) 2022
17	Zinc as Zn	mg/l	BDL (LOD 0.01)	5.0	15.0	IS:3025 (Part-65) 2022

### Note:

1. This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without our special permission in writing.
2. The sample will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified.
3. Any discrepancy in test result should be reported within 15days.
4. The above Results are related to the tested Sample Only.
5. The result listed refers only to the tested samples and applicable Parameters. Endorsement of product is neither inferred nor implied.





CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by National Accreditation Board for Testing and Calibration Laboratories  
Approved: by Bureau of International Quality Standards (ISO 45001:2018)

**Registered Office:** 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011 (M.P.), India

☎ 0751- 4099916, 223217

Email: aetrl2016@gmail.com,



## Test Report

ULR No. TC1767926000001876F


<b>Test Report No.</b>	AETRL/120526W0001		<b>D/o Report Issue</b>	15/05/2026		
<b>Dispatch No</b>	2268		<b>D/o Sample received</b>	12/05/2026		
<b>Company Name</b>	To, The Principal (Vidhya Bhavan Public School)		<b>Qty of sample</b>	1.0 Ltr		
<b>Address</b>	Kavi Nagar Airport Road Gwalior Gwalior M.P		<b>Sample bottle</b>	Poly Bottle		
S.No.	Test Parameters	Units	Results	Requirement as per IS:10500-2018		Test Method
				Acceptable Limits	Permissible Limits	
18	Copper as Cu	mg/l	BDL (LOD 0.02)	0.05	1.5	IS:3025 (Part-65) 2022
19	Total Chromium as Cr	mg/l	BDL (LOD 0.01)	0.05	No Relaxation	IS:3025 (Part-52)
20	Lead as Pb	mg/l	BDL (LOD 0.007)	0.1	No Relaxation	IS:3025 (Part-47)

  
Reviewed by

Dr. Dinesh Uchchariya

\* End of Report \*



  
Authorised Signatory  
Rajesh Jain

**Note:**

1. This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without our special permission in writing.
2. The sample will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified.
3. Any discrepancy in test result should be reported within 15days.
4. The above Results are related to the tested Sample Only.
5. The result listed refers only to the tested samples and applicable Parameters. Endorsement of product is neither inferred nor implied.





## Test Report

ULR No. TC176792600001877F

Test Report No.	AETRL/120526W0002	D/o Report Issue	15/05/2026
Dispatch No	2268	D/o Sample received	12/05/2026
Company Name	To, The Principal (Vidhya Bhavan Public School)	Qty of sample	1.0 Ltr
Address	Kavi Nagar Airport Road Gwalior Gwalior M.P	Sample bottle	Poly Bottle
Nature of Sample	Water		
Sample Collected By	Customer	D/o Sample Collection	08/05/2026
Sample Description	RO Water	Sample Received by	AETRL LAB
Sample Location	Vidhya Bhavan Public School	Sampling Method	NA
Coordinates	NA	Sample Condition	Satisfactory
D/o Sample Analysis	12/05/2026	D/o Analysis Completion	15/05/2026


## Results


S.No.	Test Parameters	Units	Results	Requirement as per IS:10500-2018		Test Method
				Acceptable Limits	Permissible Limits	
1	Total Coliform	Absent/Present/100 ml	Absent	Shall Not be detectable in any 100ml Sample	No Relaxation	IS:15185,2016(Reaff- 2021)
2	E. coli	Absent/Present/100 ml	Absent	Shall Not be detectable in any 100ml Sample	No Relaxation	IS:15185,2016(Reaff- 2021)

  
Reviewed by

Dr. Dinesh Uchchariya

\* End of Report \*



  
Authorised Signatory  
Rajesh Jain

**Note:**

1. This report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without our special permission in writing.
2. The sample will be destroyed after 15 days from the date of issue of test certificate unless otherwise specified.
3. Any discrepancy in test result should be reported within 15days.
4. The above Results are related to the tested Sample Only.
5. The result listed refers only to the tested samples and applicable Parameters. Endorsement of product is neither inferred nor implied.

